



Teton County Fire Protection District

P.O. Box 474
911 N. Hwy 33
Driggs, ID 83422

February, 27, 2025
Teton County P&Z
Planning and Zoning Hearing.

Inspirada Ranch 56 lot Subdivision.

No information was provided for a fire suppression water source. Not Approved.
Exterior Subdivision access is approved from E 2500 N.

Grimm, Aspen Meadows Lot 20 Split.

No fire related issues or concerns were noted. Approved.

Eddyline 12 Lot Subdivision.

The fire pond is approved, will need full details and drawings for final approval.
Exterior access is approved from W 4000 N.

Palisade Village 7 Lot Subdivision.

The fire pond is approved, will need full details and drawings for final approval.
Exterior access is approved from W 5250 N.

Ee-Dah-How Acres Subdivision, Gavin Lot 7 Split.

No fire related issues or concerns were noted. Approved.

Sincerely,

A handwritten signature in black ink, appearing to read "Earle Giles III".

Earle Giles III
Fire Marshal
egiles@tetoncountyfire.com
(208) 715-5201