



Hidden Springs

1386 N. 695 E.
Shelley, ID 83274

Cell: (208) 705-7200
Email: grantdurtschi@yahoo.com

WATER FLOW CERTIFICATION

Test Date: 5/28/2024

Testing Location: Victor Outpost

Type of Reservoir: Pond

In compliance with Teton County Fire Protection Resolution for Subdivisions, Article 2.3.8, the above named water source was tested. It is hereby certified that the measured flow was 900 gallons per minute.

Grant Durtschi, P.E.



Mitzi Van Arsdell <mvanarsdell@tetoncountyidaho.gov>

Agency Notices for June 10, 2025 Teton County Planning and Zoning Hearing

Earle Giles <egiles@tetoncountyfire.org>

Wed, May 21, 2025 at 2:25 PM

To: Mitzi Van Arsdell <mvanarsdell@tetoncountyidaho.gov>

Mitzi,

Planning and Zoning Hearing scheduled for June 10, 2025.Good Timber Ranch,The Variance Request found no fire related issues or concerns and is **Approved**.Back Forty 5 lot Subdivision Preliminary Plat Hearing,

The proposed fire pond shall be inspected annually to be approved for the water source used for fire suppression.

Access is approved from County Road S 1000 W .

Thank you,

Earle Giles, III

Deputy Fire Chief

Fire Marshal

Teton County Fire Protection District

egiles@tetoncountyfire.comtetoncountyfire.com

p: 208.715.5201

f: 208.936.7014

Earle Giles

Deputy Chief Prevention/Fire Marshall

t: 208-715-5201

911 N. Hwy. 33/P.O. Box 474, Driggs, ID, 83422

Web: www.tetoncountyfire.orgEmail: egiles@tetoncountyfire.org

The content of this email is confidential and intended for the recipient specified in message only. It is strictly forbidden to share any part of this message with any third party, without a written consent of the sender. If you received this message by mistake, please reply to this message and follow with its deletion, so that we can ensure such a mistake does not occur in the future.

From: Mitzi Van Arsdell <mvanarsdell@tetoncountyidaho.gov>**Sent:** Monday, May 19, 2025 12:38 PM



Mitzi Van Arsdell <mvanarsdell@tetoncountyidaho.gov>

RE: Fire pond approval

Taylor R. Cook <tcook@nelsonengineering.net>

Tue, May 20, 2025 at 3:22 PM

To: Earle Giles <egiles@tetoncountyfire.org>

Cc: Joshua Chase <jchase@tetoncountyidaho.gov>, Mitzi Van Arsdell <mvanarsdell@tetoncountyidaho.gov>

From: Earle Giles <egiles@tetoncountyfire.org>

Sent: Tuesday, May 20, 2025 2:43 PM

To: Taylor R. Cook <tcook@nelsonengineering.net>

Cc: Joshua Chase <jchase@tetoncountyidaho.gov>; Mitzi Van Arsdell <mvanarsdell@tetoncountyidaho.gov>

Subject: Re: Fire pond approval

Preliminary approval.

The proposed shared use agreement is approved and will need to be completed and submitted. The Victor Outpost fire pond is compliant with a recent inspection on 5/28/2024.

The pond shall be inspected and certified annually to be compliant.

Thank you,

Earle Giles, III

Deputy Fire Chief

Fire Marshal

Teton County Fire Protection District

egiles@tetoncountyfire.com