



## Teton County Fire Protection District

P.O. Box 474  
911 N. Hwy 33  
Driggs, ID 83422

August, 27, 2024  
Teton County P&Z  
Re: 9/10/24 ,9/11/24 Hearing.

### Rolling Stone Acres 4 lot subdivision.

Preliminary, approval for a fire pond and access from S 500 W with final approval of fire pond details.

### Eddyline 12 lot Subdivision.

Concept, approval for a fire pond and access from W 4000 N.

Will need more detailed information on the proposed water source for fire protection and interior road system and turnarounds.

### Sweetwater subdivision Phase 1.

The water source for fire suppression and current pond inspections/certifications shall be required for future development. Increased density of the building lots may require a pressurized central main hydrant system.

Access is approved from E 2500 N.

### End of the Trail subdivision.

Concept, the water source for fire suppression is approved, with approval through the city of Driggs and within one mile of the subdivision.

Access is approved from Cemetery Road 1000 E.

Sincerely,

A handwritten signature in black ink, appearing to read "Earle Giles III".

Earle Giles III  
Fire Marshal  
[egiles@tetoncountyfire.com](mailto:egiles@tetoncountyfire.com)  
(208) 715-5201