

TETON COUNTY FIRE PROTECTION DISTRICT
PO Box 474 • 911 North Hwy. 33
Driggs, Idaho 83422 • (208) 715-5201



October P&Z Hearing.

22-369 Plat Concept. No fire related issues or concerns were noted on the plat review.

Trucco-Irish Acres 10 lot Subdivision Preliminary Plat.

Approved for fire department access and engineered fire pond details. The pond shall be inspected and certified annually per the International Fire Code.

Clearwater Reserve 2 lot Subdivision Preliminary Plat.

Is approved for access, fire suppression is not required in two lot subdivisions.

Hunnidale Farms 2 lot Subdivision concept Application.

Is approved for fire department access, a water source for fire protection is not required on two lot subdivisions.

Two Thousand Views 10 lot Subdivision Improvement Plans.

Is approved for fire department access, the proposed fire pond water fill shall be a dry barrel fire hydrant as used in the cities of Victor or Driggs and inspected/certified annually per the International Fire Code.

No narrative was attached for review.

Thank you,

Earle Giles III
Fire Marshal

egiles@tetoncountyfire.com

(208) 715-5201