



Teton County Fire Protection District

P.O. Box 474
911 N. Hwy 33
Driggs, ID 83422

Jan,31,2024

Re: Harlen Ranch.

The Harlen Ranch 16 lot Subdivision,

Is approved for fire department apparatus access.

The proposed pond for the fire suppression water supply is approved and may need County review as the fill location is on the West 3500 South 1000 West Road.

The fire pond shall be inspected and tested annually per the 2018 International Fire Code.

Sincerely,

A handwritten signature in cursive script, appearing to read "Earle Giles III".

Earle Giles III
Fire Marshal

egiles@tetoncountyfire.com

(208) 715-5201