

TETON COUNTY FIRE PROTECTION DISTRICT
PO Box 474 • 911 North Hwy. 33
Driggs, Idaho 83422 • (208) 715-5201



Alpenglow 19 lot Subdivision,
Is approved for fire department access and water supply for fire suppression.

Coopers Hollow 6 lot Subdivision Preliminary Review,
Is approved for fire department apparatus access, Further details on the fire pond are required for approval.

Clearwater Reserve 2 lot Subdivision Preliminary Review,
Is approved for fire department apparatus access, fire suppression is not required.

Irish Acres 10 Lot Subdivision,
Is approved for fire department apparatus access, the proposed pond for the fire suppression water source should be reviewed for a combined pressurized water source with JC Ranches 26 lot Subdivision.

JC Ranches 26 lot Subdivision,
Is approved for fire department apparatus access and should be considered a shared pressurized water source for fire suppression with the Irish Acres Subdivision.

Peaked Mountain Ranch 12 lot plus 5 lot Subdivision,
Is approved for fire department apparatus access and fire hydrant layout. Skyline View Ranch 7 lot Subdivision,

Is approved for fire department access, The water source details for fire suppression need to be designed and engineered for approval.

Hill Special Use Permit,
Housing units may require a fire suppression and alarm system per the 2018 International Fire Code. Additional building information is required for a full review. Fire department access is approved.

Thank you,

Earle Giles III
Fire Marshal

(208) 715-5201

egiles@tetoncountyfire.com

