

TETON COUNTY FIRE PROTECTION DISTRICT  
PO Box 474 • 911 North Hwy. 33  
Driggs, Idaho 83422 • (208) 715-5201



---

Attention: Teton County P&Z

CC:

Re : Plat Applications,11-8-22

Date : 10-24-2022

Plat Applications. 11-8-2022 Planning Commission.

Albanese PUD Preliminary Plat.

The two lot Subdivision is approved for fire department access.

Skyline View Ranch 7 lot Subdivision Concept Master Plan.

Approved for fire department access only. No information was provided to review for fire a suppression water source.

Greenback 6 lot Subdivision Preliminary Plat.

Approved for fire department access and the proposed pond for fire suppression.

Lone Pine Ranch 3 lot Subdivision Concept Review.

The proposed access and pond for fire suppression is approved, further details shall be provided to include dimensions on the site plan and access to the proposed water source and fill hydrant location.

Laurel Flats Subdivision Revised Master Plan.

Approved for the shared use agreement of a water source used for fire suppression and fire department access.

A handwritten signature in black ink, appearing to read "Earle Giles, III".

10-24-2022

**EARLE GILES, III**

Deputy Fire Chief

Fire Marshal

Teton County Fire Protection District

[egiles@tetoncountyfire.com](mailto:egiles@tetoncountyfire.com)

p: 208.715.5201

f: 208.936.7014