



TETON COUNTY FIRE PROTECTION DISTRICT
PO Box 474 • 911 North Hwy. 33
Driggs, Idaho 83422 • (208) 715-5201

August 8th P&Z Hearing.

Harlan Ranch 16 lot Subdivision Preliminary Plat, is approved for fire department apparatus access and the proposed fire pond location and size for fire suppression needs.

Boundless Sky 6 lot Subdivision Preliminary Plat, is approved for fire department apparatus access and the proposed fire pond location and size for fire suppression needs.

Hidden Oaks 64 lot Subdivision Concept Hearing, will need additional reviews for fire department through water access and additional fire suppression needs due to the size of the development. Not approved.

Stallion Springs 5 lot Subdivision Preliminary Plat Hearing, Fire Pond and access will need more details for review.

Wendorff SUP Review, is approved. A fire department site inspection shall be conducted on the barn building before any events are scheduled. Maximum occupancy of the class A building shall not exceed 150 without further review of fire suppression needs.

Thank you,

Earle Giles III
Fire Marshal

egiles@tetoncountyfire.com

(208) 715-5201